



ALFRED NZO

DISTRICT MUNICIPALITY

Enquiries: **M Ntamane**

SPECIFICATION

Date: **19 July 2019**

Ref: **IDMS-WSP/6/2/2/2**

Specification for Drought Relief programme in Mekgankganeng Village.

ITEM NO.	DESCRIPTION OF ITEM	UNIT	QUANTITY
1.	Supply and installation of 10 000 litre water storage tank and their connectors; Construction of tank stand and anchors.	Lump sum	01
1.	Supply, installation and connection of 32 mm HDPE pipe with connectors; Connect pipe from the existing main pipe to the installed tank.	M	350
2.	Supply, installation and connection of 25 mm HDPE reticulation pipe with connectors.	M	100
3.	Construction of communal tap stands	NO	03


The bidders should be registered with CIDB, minimum of **1 CE / 1CEPE**

EVALUATION CRITERIA


This project will be evaluated based on the below criteria:

• BBBEE points	20
• Pricing	80
Total	100

Requested by


Acting WSP Manager
M. Ntamane

Approved / Not Approved


Acting Senior Manager: IDMS
C Ndzungu